



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: **Notice of Violation**
Wood County
West Millgrove SS Improvements
Storm Water
Construction

June 13, 2013

Mr. William Barber
Northwestern Water and Sewer District
12560 Middleton Pike
Bowling Green, Ohio 43402

Dear Mr. Barber:

On May 7, 2013, while in the area of the West Millgrove Sanitary Sewer Improvements, I observed construction activity on Cygnet Road from the Village of West Millgrove to Bradner Road, Perry Township, Wood County. The purpose of this observation was to evaluate compliance of the site with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. You currently hold CGP 2GC03079*AG for the West Millgrove Sanitary Sewer Improvements project.

Neither the Storm Water Pollution Prevention Plan (SWP3) nor inspection logs were reviewed as part of this inspection. No inlet protection was observed in the Village of West Millgrove. Nor was there sediment or erosion protection at a stream crossing about a third of a mile east of West Millgrove. *This is a violation of Part III.G.2. of the CGP. The CGP requires inlet protection and sediment control practices along stream banks.*

Once all disturbed areas are at final grade, the CGP requires permanent stabilization within seven days of reaching final grade.

Within 10 days of the date on this letter, please submit to this office **written notification** of the actions taken or proposed to prevent any future violations. Your response should include the dates, either actual or proposed, for the completion of the actions.

If you should have any questions, please contact me at 419-373-3016 or at: patricia.tebbe@epa.ohio.gov.

Sincerely,

Patricia A. Tebbe, PE
Division of Surface Water

/jim
pc: Wood County SWCD
Wood County Engineer
ec: Tracking