



John R. Kasich, Governor
Michelle Taylor, Lt. Governor
Scott J. Kally, Director

June 11, 2013

Jim Manos
Mr. Holdings of Dublin LLC
5973 Macewen Court
Dublin, OH 43017

**RE: Construction Storm Water Inspection at Brown Jug Storage/ Delaware County
Permit Number: 4GCO00090*AG**

Dear Mr. Manos:

This letter is written regarding a storm water inspection conducted by Paul Hafner and Sam Marotta of the Ohio EPA at Brown Jug Store located at 224 East William Street in Delaware County on June 4, 2013. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- Please ensure proper maintenance remains for the silt fencing that encompasses the site. Our staff noted that the corner silt fencing was removed for excavation purposes. Please ensure this fence is replaced after excavation is completed or at any time off site flow from barren areas is established.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. In addition, please provide a written response (**email preferred**) to the action items addressed above within ten days from receipt of this letter. A follow up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

HK/nsm Brown Jug Storage 6-4-2013