



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

June 10, 2013

Mrs. Connie Schneider  
Botkins Local School District  
208 North Sycamore Street  
Botkins, Ohio 45306

**RE: New K-12 Building – Botkins Local School District; NPDES Permit #1GC04498\*AG  
Compliance Inspection Findings**

Dear Mrs. Schneider:

On Friday, June 7, 2013, I inspected the new K-12 Botkins Local School District building project in Botkins, Ohio to determine compliance with the site's NPDES construction site storm water discharge permit. You were present during the site inspection.

Based on my observations, there were no obvious violations of the project's storm water discharge permit. I did review the sediment control inspections logs and the site's storm water pollution prevention plan before my inspection.

From the inspection and my review of the site's storm water pollution prevention plan, it is evident that the current erosion controls are meeting requirements under the NPDES permit. The relatively flat topography for this site reduces the chance for any large scale erosion events to occur. With our discussion about the site's storm sewer system currently being installed, I would like to remind you about the implementation of storm drain inlet protection to minimize discharge of sediment from storm water during the construction process.

No response to this inspection letter is needed at this time. If you have any questions regarding the NPDES permit, contact me at (937) 285-6357 or via email at [james.schwieterman@epa.ohio.gov](mailto:james.schwieterman@epa.ohio.gov).

Sincerely,

A handwritten signature in black ink, appearing to read "James Schwieterman", is written over a horizontal line.

James Schwieterman  
Storm Water Group  
Division of Surface Water

JS/tb

Ohio EPA DSW Storm Water Section, Construction Site Visit Information Form

Inspector initials: JS Visit date: 6/17/13 Permit # 16C044987AG

Site Name: New K-12 Building - Botkins LSD

Site Address: 404 East State Street Botkins, OH

People Contacted On Site: Connie Schneider

Phone: (937)-693-4241 E-mail: schneiderc@botkins.k12.oh.us

1. Did you see the following on site?

ITEM	YES	NO	Not Requested	Comments
NOI			/	
Coverage Letter			/	
SWP3	/			
Inspection Records	/			
Contractor & Subs signature document			✓	

2. Acreage Disturbed: 19.8

3. Site Status: Clearing/grubbing Rough Grading Storm sewers in  
 Streets in Utilities installed Final Grade Final stabilization

4. Are BMPs needed: Some

5. Are BMPs effective? All Some None No BMPs

Explain: Silt fence, Dandy bags (Flat site), Construction Entrance + Fuel container in place.

6. What post construction controls are shown on the SWP3? Yes, Storm sewer system will collect all parking lot runoff.

7. Were Photos taken & saved? Yes 8. Was an NOV issued? N/A

Additional notes/comments:

Just starting to install storm sewer system.