



John D. Kasich, Governor
Randy Taylor, Lt. Governor
Scott J. Hatfield, Director

June 14, 2013

Fischer Homes
570 Polaris Parkway
Suite 125
Westerville, OH 43082

Re: Alum Creek Village, Franklin County

To Whom it May Concern:

This letter is written in response to my storm water inspection on June 10, 2013, of Alum Creek Village, located along Alum Creek Drive, in Franklin County. Based on my site observations of the site and the conditions of the Storm Water Permit, the following items were noted.

Sediment and Erosion Controls:

1. There was no active construction at the site during the inspection. There was no erosion leaving the site and no barren areas. You are in compliance with your General Storm Water Permit.
2. Please maintain the concrete wash-out pit once construction starts again.

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3851.

Sincerely

Gregory L. Sanders
Storm Water Unit
Division of Surface Water
Central District Office

GS/nsm Alum Creek Village, June 10, 2013