



John Kasich, Governor
Mary Taylor, Lt. Governor
Scott M. Smith, Director

June 13, 2013

Hanlin Rainaldi Construction Corporation
6610 Single Tree Drive
Columbus, OH 43229

Re: Construction Storm Water Inspection at Sam's Club #6326-04, Reynoldsburg / Franklin County, Permit Number: 4GC03046*AG

Dear Sir or Madam:

This letter is written regarding my site observation of the post construction water quality treatment measures noted at Sam's Club in Reynoldsburg, Ohio on May 23 and June 5, 2013. Based on my recent evaluations of the post construction water quality plan, it is apparent that the 3-inch diameter orifice has not been installed. This orifice is necessary to accommodate the required drain times to meet the intent of the post construction water quality treatment criteria in your General Storm Water Permit.

At this time, the orifice must be installed within 14 days from receipt of this letter to avoid the potential of escalated enforcement.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

HK/nsm Sams's Club #6326-04 Reynoldsburg 5-28-2013