



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott L. Walby, Director

June 13, 2013

Chuck Evans
Schottenstein Real Estate Group
2 Easton Oval, Suite 510
Columbus, Ohio 43219

**Re: Notice of Termination Inspection at Ety Road Apartments / Fairfield County
Permit Number: 4GC03649*AG**

Dear Mr. Evans,

This letter is written in follow-up to a construction storm water inspection by Brittany Turner, Paul Hafner, and Sam Marotta of the Ohio EPA, at the Ety Road Apartments located at the northeast corner of Ety Road and Riverway Drive on May 28, 2013. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

It appeared during the inspection that construction activity has been completed for this site. A Notice of Termination form is required provided the following items are addressed:

- All areas must be protected from erosion measured by a minimum vegetative density of 70 percent for all disturbed areas.
- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction mandates can be found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria with your submittal.
- If the vegetative requirements above are met please submit your Notice of Termination (NOT) concurrent with your submittal of the post construction verification. The NOT form can be found at: http://www.epa.state.oh.us/portals/35/documents/NOT_app_fis.pdf

Chuck Evans
Schottenstein Real Estate Group
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

HK/nsm Ety Road Apts. 5-28-13