



John R. Kasich, Governor
Mark F. Norci, Lt. Governor
Paul J. Wieg, Director

June 14, 2013

Emily Zambuto
Landfill Energy Systems
2999 Judge Road
Oakfield, New York 14125

Re: **Construction Storm Water Inspection at LES Renewable NG LLC / Franklin County. Permit Number: 4GC04104 *AG**

Dear Ms. Zambuto:

This letter is written regarding a storm water inspection conducted by Sam Marotta and Elizabeth Pleta, of the Ohio EPA at LES Renewable NG LLC located at 4065 London Groveport Road on June 3, 2013. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- Silt fencing should be properly maintained to ensure proper function condition.
- Please maintain positive storm water flow from all affected areas to the impoundments intended for sediment control
- Inlet protections are required provided the storm sewer system is not routed to an approved centralized sediment basin or demonstrate an acceptable alternative (Figure 1).
- During the inspection, it was noted that the temporary riser was not effectively sealed to the outlet structure. This results in the elimination of all effective sediment storage. Corrective measures must be taken to seal the riser to the outlet structure to ensure ponding.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. In addition, please provide a written response (**email preferred**) to the action items addressed above within ten days from receipt of this letter. A follow up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

HK/nsm LES Renewable NF LLC 6-3-13



Figure 1: Proper inlet protection required for proper future functioning.