

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Walby, Director

June 14, 2013

Ed Minhinnick  
Asphalt Services of Ohio  
4579 Poth Road  
Whitehall, OH 43213

**Re: Storm Water Inspection at Main Office / Franklin County  
Permit Number: 4GC04132\*AG**

Dear Mr. Minhinnick:

This letter is written in follow-up to a construction storm water inspection by Brittany Turner of the Ohio EPA, at the Main Office located at 4579 Poth Road in Whitehall on May 31, 2013. The purpose of the inspection was to evaluate compliance with Ohio EPA's General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

**Sediment and Erosion Controls:**

- The entrance of the site must be stabilized to minimize off site vehicle tracking (See Figure 1).
- The silt fence on site has failed and will require maintenance or reinstallation at this time (See Figure 2, 3, & 4).
- Please be aware that the General Permit indicates that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on site for the agency to review.

**21 Day Rule:**

- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days (See Figure 5).

Ed Minhinnick  
Asphalt Services of Ohio  
Page 2


If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,

A handwritten signature in black ink, appearing to read 'HK', is written over the word 'Sincerely,'.

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

HK/nsm Main Office 5-31-13




**Figure 1: Needs non erodible entrance**



**Figure 2: Silt fence requires maintenance**



**Figure 3: Silt fence requires entrenchment**



**Figure 4: Silt fence requires entrenchment**

Main Office  
Big Walnut Creek Watershed  
Drawn by Elizabeth Turner  
2012/2013

Figure 5: 21 day rule