



John R. Kasich, Governor
 Mary Taylor, Lt. Governor
 Scott J. Nally, Director

June 17, 2013

Re: Athens County
 Happy Valley Estates MHP
 Self-Monitoring Report Violations
 Ohio EPA Permit 0PV00531*BD

Mr. Asa Elsea, President
 Elsea, Inc.
 P.O. Box 580
 Circleville, Ohio 43113

We have received your self-monitoring report covering the month of May 2013 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Type	Date	Reporting Code	Parameter	Limit Type	Permit Limit	Reported Value
001	Limit	5/1/2013	00530	Total Suspended Solids	Monthly Conc.	12	43.75
001	Limit	5/1/2013	00530	Total Suspended Solids	Monthly Load	0.636	3.03122
001	Limit	5/7/2013	00530	Total Suspended Solids	Daily Conc.	18	40.
001	Limit	5/7/2013	00530	Total Suspended Solids	Daily Load	0.954	5.1476
001	Limit	5/13/2013	00530	Total Suspended Solids	Daily Conc.	18	56.
001	Limit	5/13/2013	00530	Total Suspended Solids	Daily Load	0.954	5.08704
001	Limit	5/20/2013	00530	Total Suspended Solids	Daily Conc.	18	62.
001	Limit	5/20/2013	00530	Total Suspended Solids	Daily Load	0.954	1.47842
001	Limit	5/1/2013	00610	Nitrogen, Ammonia (NH3)	Monthly Conc.	1.0	24.75
001	Limit	5/1/2013	00610	Nitrogen, Ammonia (NH3)	Monthly Load	0.053	1.57047
001	Limit	5/7/2013	00610	Nitrogen, Ammonia (NH3)	Daily Conc.	1.5	18.7
001	Limit	5/7/2013	00610	Nitrogen, Ammonia (NH3)	Daily Load	0.080	2.4065
001	Limit	5/20/2013	00610	Nitrogen, Ammonia (NH3)	Daily Conc.	1.5	30.8
001	Limit	5/20/2013	00610	Nitrogen, Ammonia (NH3)	Daily Load	0.080	.73444
001	Limit	5/15/2013	50060	Chlorine, Total Residual	Daily Conc.	0.019	.16
001	Limit	5/29/2013	50060	Chlorine, Total Residual	Daily Conc.	0.019	.2
001	Limit	5/1/2013	80082	CBOD 5 day	Monthly Conc.	10	35.5
001	Limit	5/1/2013	80082	CBOD 5 day	Monthly Load	0.53	2.90007
001	Limit	5/7/2013	80082	CBOD 5 day	Daily Conc.	15	47.
001	Limit	5/7/2013	80082	CBOD 5 day	Daily Load	0.795	6.04843
001	Limit	5/13/2013	80082	CBOD 5 day	Daily Conc.	15	49.

Station	Type	Date	Reporting Code	Parameter	Limit Type	Permit Limit	Reported Value
001	Limit	5/13/2013	80082	CBOD 5 day	Daily Load	0.795	4.45116
001	Limit	5/20/2013	80082	CBOD 5 day	Daily Conc.	15	36.
001	Limit	5/20/2013	80082	CBOD 5 day	Daily Load	0.795	.85844

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets and U.S. EPA's Facility Pollution Prevention Guide, (EPA/600/R-92/088), you may contact the Ohio EPA Pollution Prevention Section at (614) 644-3469 or me for additional information.

If there are any questions, please contact this office.

Sincerely,



Nicholas G. Hammer
Environmental Specialist
Permits and Compliance Section
Division of Surface Water

NH/dh