



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



June 13, 2013

RE: MCDONALDS-MINERVA
3GC06417*AG
STORMWATER
STARK COUNTY

Dave Gnatowski
McDonalds Real Estate Company
2 Easton Oval, Suite 200
Columbus, OH 43219

Dear Mr. Gnatowski:

On June 5, 2013 this writer inspected the above referenced construction site for the purpose of determining compliance with General Construction NPDES Permit No. 3GC06417*AG. The site is located at 601 E. Lincolnway, Minerva, Stark County. I was accompanied by William Reed, Project Superintendent, Fred Olivieri Construction Company. Below is a summary of my observations:

- 1) The NOI, copy of the permit and Stormwater Pollution Prevention Plan (SWPPP) were present in the construction trailer. I did a cursory review of the SWPPP. It appeared to be fairly complete. Please be advised that with the new Construction General NPDES Permit OHC000004, there may be required updates to the SWPPP. One important one for your project concerns the proposed Bioretention Cell located on the north side of the site near E. Lincolnway. The drawdown time has been changed to 24 hours. The cell will have to be redesigned to accommodate the reduction in time.
- 2) The one storm water catch basin near the construction trailer must be upgraded to include the chicken wire and two by four supports behind the silt fence fabric.
- 3) The rest of the site appeared to be in good shape.

Please forward a copy of the Updated SWPPP and Bioretention Cell to this office no later than June 28, 2013, for our review. If you should have any questions concerning any of the above, feel free to contact this writer at (330) 963-1136 or by e-mail at phil.rhodes@epa.ohio.gov.

Sincerely,

Philip P. Rhodes, P.E.
Environmental Specialist II
Division of Surface Water

PPR:ddw

cc: Julie Barbari, Stark Soil and Water Conservation District
File: Stormwater/Construction, Stark County, Minerva