



Gov. R. Kasich, Governor
Lt. Gov. Ted Strickland, Lt. Governor
Chris Salvi, Director

June 13, 2013

Al Coughlin
Coughlin Automotives
71 East Wilson Bridge Road
Worthington, OH 43085

**Re: Storm Water Inspection at Pataskia Town Center/ Licking County
Permit Number: 4GC01147*AG**

Dear Mr. Coughlin:

This letter is written in follow up to a construction stormwater inspection I conducted at Coughlin Automotive located on State Route 16 on June 4, 2013. The purpose of the inspection was to evaluate compliance with Ohio EPA's General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

Post Construction

- It appears measures have been taken to eliminate extended detention for the large centralized impoundment. Please be aware you are under consent order to ensure post construction water quality treatment measures as depicted in the general stormwater permit. Please respond with your intentions to implement the corrective measures to ensure compliance with your General Storm Water Permit.

I understand that there are vacant lots associated with this development. I am unclear whether or not future development is ongoing for this site and suggests a meeting to discuss the appropriate best management practices concurrent with all phases of development. Please contact me at upon receipt of this letter at 614-728-3844

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

HK/nsm Coughlin Automotive 6-10-13