



John E. Kasicki, Governor
Mary Taylor, Lt. Governor
Scott A. Bortz, Director

June 18, 2013

Michael Murphy
Murphy Development Company
4393 Arbor Lake Drive
Groveport, OH 43125

Re: Cobbleton Grove Condominiums / Franklin County

Dear Mr. Murphy:

This letter is written regarding the storm water inspection that I conducted on June 12, 2013, at Cobbleton Grove Condominiums, located along Ebright Road, in Franklin County. I understand that these construction activities are covered under the General Storm Water Permit Associated with Construction Activities. Based on my site inspection and the General Storm Water Permit, the following items must be addressed:

Sediment and Erosion Controls:

There did not appear to be any construction activity at the site. The site was stabilized mostly with weeds, but no erosion was leaving the site. Please be aware that if construction activities commence that the General Permit mandates that all barren areas which remain idle areas in excess of 21 days be protected from erosion (i.e., seed and straw), within seven days from the last construction activity.

If you have any questions regarding this letter or my inspection, please do not hesitate to call me at our Central District Office at (614) 728-3851.

Sincerely,

Gregory L. Sanders
Storm Water Unit
Division of Surface Water
Central District Office

GS/nsm Cobbleton Grove Condos, June 12, 2013