



40 years and moving forward

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

June 18, 2013

Jeff Acuff
Mountain Agency LLC
401 Milford Parkway
Suite A
Milford, OH 45150

**Re: Jeff Wyler Chevrolet / Franklin County
General Storm Water Permit #4GC04115*AG**

Dear Mr. Acuff:

This letter is written regarding the storm water inspection that I conducted on June 12, 2013, at Jeff Wyler Chevrolet, located at 5885 Gender Road, in Canal Winchester, Ohio. I understand that these construction activities are covered under the General Storm Water Permit Associated with Construction Activities. There was active construction during my inspection. The purpose of the inspection was to ensure continued compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following:

Sediment and Erosion Controls:

- The perimeter of the site had erosion controls installed. However, there were two swales that could discharge sediment off-site. I spoke with your contractor and requested that he install sediment trap on the two swales. The storm water pollution prevention plan (SWP3) will need to be revised to show the sediment traps or other additional erosion controls that will be installed at the site.
- Please be aware that the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days. There was a stockpile that will also need to be stabilized if it remains idle.
- Your contractor, Seals Construction, will need to complete and submit a construction storm water co-permittee notice of intent application. This application may be obtained at the following weblink:
- <http://www.epa.state.oh.us/dsw/storm/stormform.aspx>. Seals Construction is considered an operator per the construction permit. "Operator" means any party associated with a construction project that meets either of the following two criteria:

1. The party has operational control over construction plans and specifications, including the ability to make modifications to those plans and specifications; or
2. The party has day-to-day operational control of those activities at a project which are necessary to ensure compliance with an SWP3 for the site or other permit conditions (e.g., they are authorized to direct workers at a site to carry out activities required by the SWP3 or comply with other permit conditions). As set forth in Part II.A, there can be more than one operator at a site and under these circumstances, the operators shall be co-permittees.

If you have any questions regarding this letter or my inspection, please do not hesitate to call me at our Central District Office at (614) 728-3851.

Sincerely,



Gregory L. Sanders
Storm Water Unit
Division of Surface Water
Central District Office

c: Andy Seals, Seals Construction