



John R. Kasich, Governor
 Mary Taylor, Lt. Governor
 Scott J. Nally, Director

June 18, 2013

Re: Coshocton County
 New PK-6 Elementary School
 Storm Water Construction Activity
 Notice of Violation
 Permit OGC01603*AG

Mr. David Hire
 Coshocton City Schools
 1207 Cambridge Road
 Coshocton, Ohio 43812

Dear Mr. Hire:

On June 3, 2013, I visited your site on Cambridge Road. The purpose of the inspection was to determine the compliance of this site with the National Pollutant Discharge Elimination System (NPDES) permit for discharges of stormwater associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. I have the following comments:

Permit Coverage:

1. Part III.G.2.b.i. (Table 2) of the permit requires that any area that will lie dormant for more than 21 days, but less than a year be stabilized within 7 days of the most recent disturbance.

Table 2: Temporary Stabilization

Area Requiring temporary stabilization	Time frame to apply erosion controls
Any disturbed areas within 50 feet of a surface water of the State and not at final grade	Within two days of the most recent disturbance if the area will remain idle for more than 21 days
For all construction activities, any disturbed areas that will be dormant for more than 21 days but less than one year, and not within 50 feet of a surface water of the state	Within seven days of the most recent disturbance within the area For residential subdivisions, disturbed areas must be stabilized at least seven days prior to transfer of permit coverage for the individual lot(s)
Disturbed areas that will be idle over winter	Prior to the onset of winter weather

At the time of inspection, several areas within the site appeared to have been bare for an extended period of time. Any area that will remain idle for more than 21 days must be temporarily stabilized.

2. In accordance with Part III.G.2.d.i. and Part III.G.2.h. of the permit, all sediment control structures shall be functional throughout the course of earth disturbing activities. Sediment controls should be in place prior to the onset of construction activities and must remain in place until the entire up slope area is stabilized.


At the time of inspection, several sections of silt fence along the stream on the downslope of the site were in need of clearing or replacement. Dandy bags appeared to be blinded beyond the point of functionality and were no longer draining. Since the dandy bags in question drain to a sediment control pond they are not necessary for compliance with this permit. Please repair or replace the controls immediately.

Sediment and erosion controls for your site must meet the guidelines and design criteria set forth in the above mentioned *Rainwater and Land Development* manual. A copy of this manual may be obtained by contacting the Ohio Department of Natural Resources, Division of Soil and Water Conservation, at (614) 265-6610.

Violators of ORC 6111 may be fined up to \$10,000 per day of violation. In addition, federal law allows for third party lawsuits for failure to comply with your NPDES permit.

Within fourteen (14) days of receipt of this letter, please submit to me at this office a written notification as to actions taken or proposed to eliminate violations of the permit. Your response should include the dates, either actual or proposed, for the completion of the actions. If you have any questions, please contact me at (740) 380-5447.

Sincerely,



Joe Cook
Storm Water Section
Division of Surface Water

JC/dh