



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

June 18, 2013

Re: Guernsey County
Speedway Store #100211
Storm Water Construction Activity
Permit OGC01944*AG

Jeffery Wild
Speedway LLC
500 Speedway Drive
Enon, Ohio 45323

Mike Grady
Robertson Construction
1801 Thornwood Drive
Heath, Ohio 43056

Dear Mr. Wild:

On May 31, 2013, I visited the site located on Wintergreen Road that has a construction storm water permit with the Ohio EPA. The purpose of my inspection was to determine the compliance of this site with the National Pollutant Discharge Elimination System (NPDES) permit for discharges of storm water associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111.

No violations of the terms and conditions of the permit were discovered. As I discussed with Mr. Grady, we recommend installing silt fence along each of the unused entrances to the project and using inlet protection on all catch basins. Considering the slope of the project, it appears that all the storm water will run to the site entrance. Please pay special attention to the construction site entrance and be mindful of runoff off site.

As a reminder, if your project disturbs more than five acres you are required to implement post construction water quality volume storage requirements with permanent storm water management structures as required by the permit.

If there are any questions, please contact Aaron Wolfe at (740) 380-5277 or me at (740) 380-5447.

Sincerely,

A handwritten signature in black ink, appearing to read "J. S. Cook". The signature is stylized and written in a cursive-like font.

Joe Cook
Storm Water Section
Division of Surface Water

JC/dh