



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

June 24, 2013

Mr. Daniel Weaver
Ferguson Construction Co.
400 Canal Street – P.O. Box 726
Sidney, OH 45365

**RE: Midwest Express Group; NPDES Permit #1GC04601*AG
Compliance Inspection Findings**

Dear Mr. Weaver:

On Tuesday, June 18, 2013, I inspected the Midwest Express Group site in East Liberty, Ohio, to determine compliance with the site's NPDES construction site storm water discharge permit. I talked to Dexter Hicks, the project supervisor, at the time of the inspection.

Based on my observations, there were no obvious violations of the project's storm water discharge permit. I did review the sediment control inspections logs and the site's storm water pollution prevention plan during my inspection.

The grade of the site looked near completion around the Midwest Express Group building. Just as a reminder, any disturbed areas at final grade must be permanently stabilized within seven days of reaching final grade within that area.

If you have any questions regarding the NPDES permit, you may contact me at (937) 204-1002 or via email james.schwieterman@epa.ohio.gov.

Sincerely,

James Schwieterman
Storm Water Group
Division of Surface Water

JS/tb

cc: Dexter Hicks

Ohio EPA DSW Storm Water Section, Construction Site Visit Information Form

Inspector initials: JS Visit date: 6/15/13 Permit # 16C04601*AG

Site Name: Midwest Express Group

Site Address: 11990 TWR RD 208 East Liberty, OH Logan CO

People Contacted On Site: Dexter Hicks

Phone: 937-498-2381 E-mail: _____

1. Did you see the following on site?

ITEM	YES	NO	Not Requested	Comments
NOI			/	
Coverage Letter			/	
SWP3	✓			
Inspection Records	✓			
Contractor & Subs signature document			/	

2. Acreage Disturbed: 9.1

3. Site Status: Clearing/grubbing Rough Grading Storm sewers in - Installing Catch basins
 Streets in Utilities installed Final Grade Final stabilization

4. Are BMPs needed: Yes

5. Are BMPs effective? All Some None No BMPs

Explain: Silt fence in rear of site, Rip rap in place

6. What post construction controls are shown on the SWP3? Sediment Pond: Storm water
from East side + West side drain into Pond
- swale / marsh dike running along outside of property

7. Were Photos taken & saved? Yes 8. Was an NOV issued? no

Additional notes/comments:

- Silt fence in rear of site could be removed
- Stabilize barren soil as soon as possible (7 days of most recent disturbance)