



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

June 25, 2013

Re: Tuscarawas County
Tolloty Incubator
Storm Water Construction Activity
Permit #OGC01981*AG

Mr. Doug Ugie
Jeffrey Carr Construction
P.O. Box 1051
Massillon, Ohio 44648

Mr. Keith Bush
Kent State University
P.O. Box 5190
Kent, Ohio 44242

Dear Mr. Bush and Mr. Ugie:

On June 4, 2013, I visited the site located on Tech Park Drive that has a construction storm water permit with the Ohio EPA. The purpose of my inspection was to determine the compliance of this site with the National Pollutant Discharge Elimination System (NPDES) permit for discharges of storm water associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111.

No violations of the terms and conditions of the permit were discovered. Please continue to implement permit requirements as construction continues. Be sure to support areas of silt fence that see heavy runoff and sediment loading.

As a reminder, if your project disturbs more than five acres you are required to implement post construction water quality volume storage requirements with permanent storm water management structures as required by the permit.

If there are any questions, please contact Aaron Wolfe at (740) 380-5277 or myself at (740) 380-5447.

Sincerely,

Clinton Kuenzli
Storm Water Section
Division of Surface Water

CDK/dh