



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

June 24, 2013

Richard C. Westerfield  
City of Columbus Division of Power and Water  
910 Dublin Road  
Columbus, OH 43215

**Re: Construction Storm Water Inspection at Dublin Road WTP / Franklin County  
Permit Number: 4GC04032 \*AG**

Dear Mr. Westerfield:

This letter is written regarding a storm water inspection conducted by Sam Marotta and Paul Hafner, of the Ohio EPA at the Dublin Road WTP located at 940 Dublin Road on May 31, 2013. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

**Sediment and Erosion Control:**

- Our staff noted that the silt fencing around the perimeter of the site was not entrenched four to six inches. Please ensure the corrective measures are taken to repair the silt fencing within seven days of receipt of this letter.
- It appeared to our staff that the drainage from the site was draining properly to a series of ponds located on the south and east portion of the site. Please continue to ensure positive drainage to the impoundments intended for sediment control. Modified outlet structures designed specifically for sediment control must be maintained during this process.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days. This specifically refers to the stock piles East of Old Dublin Road.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us).

Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: George W. Bates, PE Senior Construction Manager H.R. Gray [gbates@hrgray.com](mailto:gbates@hrgray.com)  
Dennis A. Perkins, PE Construction Manager Dynotec [dperkins@dynotecinc.com](mailto:dperkins@dynotecinc.com)

HK/nsm Dublin Road WTP 5-31-13