



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

June 27, 2013

Re: Morgan County
Burr Oak State Park
Storm Water Construction Activity
Permit #0GC01929*AG

Mr. Mike Powers
ODNR Division of Parks & Recreation
2045 Morse Road, Bldg. C-3
Columbus, Ohio 43229

Dear Mr. Powers:

On May 29, 2013 I visited the site located at 10220 Burr Oak Lodge Road that has a construction storm water permit with the Ohio EPA. The purpose of my inspection was to determine the compliance of this site with the National Pollutant Discharge Elimination System (NPDES) permit for discharges of storm water associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statues, Ohio Revised Code (ORC) Chapter 6111.

At the time of the inspection, the project did not appear to have begun. When the project does begin, you must implement storm water controls as outlined in Ohio EPA Permit OHC000003.

As a reminder, if your project disturbs more than five acres you are required to implement post construction water quality volume storage requirements with permanent storm water management structures as required by the permit.

If there are any questions, please contact Aaron Wolfe at (740) 380-5277 or myself at (740) 380-5447.

Sincerely,

A handwritten signature in black ink that reads "Clinton Kuenzli".

Clinton Kuenzli
Storm Water Section
Division of Surface Water

CDK/dh