



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

June 28, 2013

Re: Vinton County
Lake Hope State Park Lodge
Storm Water Construction Activity
Permit # OGC01553*AG

Mr. Coy Lehman
Lake Hope State Park
27331 State Route 278
McArthur, Ohio 45651

RVC Architects, Inc.
131 W. State Street
Athens, Ohio 45701

Dear Mr. Lehman:

On May 31, 2013, I visited the site located on State Route 278 that has a construction storm water permit with the Ohio EPA. The purpose of my inspection was to determine the compliance of this site with the National Pollutant Discharge Elimination System (NPDES) permit for discharges of storm water associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111.

No violations of the terms and conditions of the permit were discovered. Please continue to implement permit requirements as construction continues. To ensure adequate vegetation coverage is achieved, Ohio EPA recommends the following:

- **Remove excess straw from the bottom of the hill and other parts of the property**
- **Place new seed and straw down, where needed, in order for vegetation coverage to increase**

As a reminder, if your project disturbs more than five acres you are required to implement post construction water quality volume storage requirements with permanent storm water management structures as required by the permit.

If there are any questions, please contact Aaron Wolfe at (740) 380-5277 or myself at (740) 380-5447.

Sincerely,

A handwritten signature in black ink that reads "Jared Kemper". The signature is written in a cursive, flowing style.

Jared Kemper
Storm Water Section
Division of Surface Water

JK/dh