Ohio EPA
40 years and moving forward

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

June 28, 2013

Re: Harrison County
CBC Services, Inc. Cadiz
Storm Water Construction Activity
Permit # 0GC01916*AG

Mr. Rodger Hutto
CBC Services, Inc.
271 5th Street NW
Carrollton, OH 44615

Dear Mr. Hutto:

On June 4, 2013, I visited the site located on Piedmont Road that has a construction storm water permit with the Ohio EPA. The purpose of my inspection was to determine the compliance of this site with the National Pollutant Discharge Elimination System (NPDES) permit for discharges of storm water associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statues, Ohio Revised Code (ORC) Chapter 6111.

No violations of the terms and conditions of the permit were discovered. Please continue to implement permit requirements as construction continues. To ensure adequate vegetation coverage is achieved, Ohio EPA recommends that the area be reseeded.

As a reminder, if your project disturbs more than five acres you are required to implement post construction water quality volume storage requirements with permanent storm water management structures as required by the permit.

If there are any questions, please contact Aaron Wolfe at (740) 380-5277 or myself at (740) 380-5447.

Sincerely,

Jared Kemper

Jared Kemper
Storm Water Section
Division of Surface Water

JK/dh