



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

Re: Fulton County  
Stormwater  
Construction Activity  
Permit No. 2GC01513\*AG

July 2, 2013

Mr. Michael T. Schueler  
Bunnell Hill Development Company Inc.  
3000-G Henkle Drive  
Lebanon, Ohio 45036

Dear Mr. Schueler:

On October 24, 2006, the Bunnell Hill Development Company received coverage under the Ohio EPA General Permit for Storm Water Associated with Construction Activity (CGP) for the construction of the Tractor Supply Co at 265 West Airport Road, City of Wauseon, Fulton County. This CGP is still active and Mr. Larry Sims was named as a contact for this site.

On June 12, 2013, I performed an inspection of this facility. The purpose of this visit was to evaluate compliance of the site with the CGP. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. As a result of this inspection, it appears that coverage for this site is eligible to be terminated.

Construction activities have been completed with final stabilization achieved on all portions of this site. The CGP requires that a Notice of Termination (NOT) be filed to relieve the applicant of the obligation to comply with the terms and conditions of this general permit including regular inspections of the site. I am enclosing an NOT form for the CGP that was issued and instructions to terminate this permit.

Please submit this form to: Ohio Environmental Protection Agency  
General Permit Program  
P.O. Box 1049  
Columbus, Ohio, 43616-1049

I have made this request two times previously. Until the CGP is terminated, the terms and condition of the CGP must be followed, which includes inspecting the storm water controls on a weekly basis and within 24 hours after any storm event greater than one-half inch of rain per 24 hour period. Records of these inspections are to be maintained and kept for review. If you do not wish to terminate coverage of this permit, please submit to me all inspection records for the past three years.

If there are any questions, please contact me at (419) 373-3016 or by e-mail at [patricia.tebbe@epa.ohio.gov](mailto:patricia.tebbe@epa.ohio.gov).

Sincerely,

Patricia A. Tebbe, P.E.  
Division of Surface Water

/jlm  
Enclosures  
ec: Tracking