



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: **Notice of Violation**
Sandusky County
Village of Woodville
NPDES 2PB00052

July 2, 2013

Mr. Keith Kruse
Village of Woodville
219 West Main Street
P.O. Box 156
Woodville, Ohio 43469

Dear Mayor & Council:

Review of your self-monitoring reports for the six month period ending in March 2013 indicates that you were in significant non-compliance (SNC) with the Total Suspended Solids effluent limitation contained in your National Pollutant Discharge Elimination System (NPDES) permit. Enclosed is a list of violations for this facility for the period of October 2012 through May 2012.

A facility is considered to be in SNC when it exceeds the effluent limit for four or more months in two consecutive quarters or exceeds the effluent limit significantly in any two months in two consecutive quarters.

Achieving compliance with Ohio's environmental laws is a primary focus of Ohio EPA in order to reduce risks to public health and welfare.

As previously discussed, you are currently taking steps to address compliance issues. Additionally, the Village has completed the sewer separation project as per the approved Long Term Control Plan (LTCP) and has authorized the process of connecting sewer taps to the separate sanitary sewer.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in your Part III-General Conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code (ORC) Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at 419-373-3014.

Yours truly,


Mary Beth Cohen
Division of Surface Water

/jlm
Enclosure
ec: Ohio EPA Inspection tracking

Village of Woodville WWTP
 2PB00052 (001) Effluent Limit Violations
 October 2012 thru May 2013

Reporting Period	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
October 2012	31648	E. coli	7D Conc	284	1187.43	10/1/2012
October 2012	31648	E. coli	7D Conc	284	3346.64	10/22/2012
December 2012	00530	Total Suspended Solids	7D Qty	40.0	46.0028	12/8/2012
February 2013	00530	Total Suspended Solids	7D Qty	40.0	59.2731	2/22/2013
March 2013	00530	Total Suspended Solids	7D Qty	40.0	57.038	3/8/2013
March 2013	00530	Total Suspended Solids	7D Qty	40.0	42.4733	3/15/2013
March 2013	00530	Total Suspended Solids	30D Conc	25.0	26	3/1/2013
March 2013	00530	Total Suspended Solids	30D Qty	28.0	48.4853	3/1/2013
March 2013	00530	Total Suspended Solids	7D Qty	40.0	68.8396	3/22/2013
March 2013	80082	CBOD 5 day	30D Qty	17.0	20.987	3/1/2013
March 2013	80082	CBOD 5 day	7D Qty	26.0	27.2362	3/22/2013
April 2013	00530	Total Suspended Solids	7D Conc	35.0	43.5	4/1/2013
April 2013	00530	Total Suspended Solids	7D Conc	35.0	64.5	4/8/2013
April 2013	00530	Total Suspended Solids	7D Qty	40.0	113.455	4/8/2013
April 2013	00530	Total Suspended Solids	7D Conc	35.0	46.5	4/15/2013
April 2013	00530	Total Suspended Solids	7D Qty	40.0	90.2325	4/15/2013
April 2013	00530	Total Suspended Solids	30D Conc	25.0	50.625	4/1/2013
April 2013	00530	Total Suspended Solids	7D Conc	35.0	48	4/22/2013
April 2013	00530	Total Suspended Solids	30D Qty	28.0	78.5638	4/1/2013
April 2013	00530	Total Suspended Solids	7D Qty	40.0	72.0361	4/22/2013
April 2013	80082	CBOD 5 day	30D Qty	17.0	19.5428	4/1/2013
May 2013	50060	Chlorine, Total Residu	1D Conc	0.038	1.197	5/1/2013
May 2013	00530	Total Suspended Solids	7D Conc	35.0	54	5/1/2013
May 2013	00530	Total Suspended Solids	7D Qty	40.0	71.3415	5/1/2013
May 2013	00530	Total Suspended Solids	7D Conc	35.0	67.5	5/8/2013
May 2013	00530	Total Suspended Solids	7D Qty	40.0	59.8976	5/8/2013
May 2013	00530	Total Suspended Solids	7D Conc	35.0	50.5	5/15/2013
May 2013	00530	Total Suspended Solids	7D Qty	40.0	43.5634	5/15/2013
May 2013	00530	Total Suspended Solids	30D Conc	25.0	56.75	5/1/2013
May 2013	00530	Total Suspended Solids	7D Conc	35.0	55	5/22/2013
May 2013	00530	Total Suspended Solids	30D Qty	28.0	55.6186	5/1/2013
May 2013	00530	Total Suspended Solids	7D Qty	40.0	47.672	5/22/2013