



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Palfy, Director

July 1, 2013

Ross Sanford
Lincoln Construction
4790 Shuster Road
Columbus, OH 43214

**Re: Storm Water Inspection at Utica Animal Care Center / Knox County
Permit #: 4GC03975*AG**

Dear Mr. Sanford:

This letter is written in follow-up to a construction storm water inspection by Rachel Bellis and Elizabeth Pleta of the Ohio EPA, at Utica Animal Care Center located at 145 North Main Street on June 13, 2013. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

Sediment and Erosion Controls:

- Please be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days. Temporary and/or permanent erosion control measures are expected within seven days of the receipt of this letter. (See **Figure 1.**)

Post Construction Requirements:

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipollitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

Ross Sanford
Lincoln Construction
Page 2

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. In addition, please provide a written response (**email preferred**) to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Ohio EPA, Division of Surface Water
Central District Office

HK/nsm Utica Animal Hospital 6-13-2013



Figure 1: Barren area surrounding drainage pond