

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott A. Hildy, Director

July 1, 2013

Duane Astrauskas
Phoenix EDT Holdings LLC
720 South Ewing Street
Lancaster, OH, 43130

**Re: Construction Storm Water Inspection at Phoenix Electrotek LLC/ Fairfield
County Permit Number: 4GC04108 *AG**

Dear Mr. Astrauskas:

This letter is written regarding a storm water inspection conducted by Brittany Turner and Jerome Hoke of the Ohio EPA at Phoenix Electrotek LLC located at 890 Mill Park Drive, Lancaster, Ohio on June 13, 2013. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit associated with Construction Activities. This was previously reported in a letter from May 28, 2013. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- It appears this site in its entirety drains to a large centralized basin. Please indicate in your response letter if this basin is designed specifically for sediment control and is owned and operated by the permittee. Please ensure positive drainage to the site during all phases of construction (see Fig. 1).
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days. This specifically applies to the stockpile on the further most south end of the project.

Duane Astrauskas
Phoenix EDT Holdings LLC
Page 2

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. In addition, please provide a written response (*email preferred*) to the action items addressed above within ten days from receipt of this letter. A follow up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Ohio EPA, Division of Surface Water
Central District Office

HK/nsm Phoenix Electrotek LLC 6-13-13




Fig 1: Water Basin that runoff appears to be draining into.