



John Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott L. Bullock, Director

July 1, 2013

Bill Heifner  
Riener Construction  
2164 City Gate Drive  
Columbus, OH 43219

**Re: Notice of Violation at Chesrown Cheverolet, Buick & GMC / Delaware County. Permit #: 4GCO00099\*AG**

Dear Mr. Heifner:

This letter is written regarding a storm water inspection I conducted with Jerome Hoke and Rachel Bellis of the Ohio EPA at Chesrown Cheverolet, Buick, GMC located on Hull Drive in the city of Delaware on June 19, 2013. The Agency understands these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items must be addressed:

**Sediment and Erosion Controls:**

- Two primary sediment basins have not been installed per the approved plan, resulting in direct violation of the Olentangy General Permit. According to the approved storm water pollution prevention plan, sediment basins are required prior to initial grading activities.
- During the inspection, we spoke with the superintendent, who agreed to install the basins within 7 days. Please ensure positive flow to the basins intended for sediment control for all affected areas during active construction.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

Bill Heifner  
Riener Construction  
Page 2

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us). In addition, please provide a written response (*email preferred*) to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,



Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office