



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: **Notice of Violation**
Wood County
Riverview Mobile Home Park
Ohio EPA Permit No. 2PY00061
NPDES Permit No. OH0135607

July 5, 2013

Mr. Steve Shipperbottom
22423 West River Road
Grand Rapids, Ohio 43522

Dear Mr. Shipperbottom:

A review of the self-monitoring reports for the referenced facility covering the months of December 2012 through May 2013 indicates violations of the conditions of your National Pollutant Discharge Elimination System (NPDES) permit. The specific instances of non-compliance are enclosed on a separate table.

This facility was in significant non-compliance (SNC) for pH for the period of July 1, 2012, through December 31, 2012. The last violation this facility incurred for pH was in January 2013, so it appears that your operator was able to control the pH violations. However, you have Dissolved Oxygen violations every month from December 2012 to May 2013. If these violations continue to occur, you may place yourself in a position of being back in SNC with the NPDES permit. When a facility is in SNC, Ohio EPA will consider escalated enforcement action.

Please inform this office in writing, within 10 days of receipt of this letter, as to the description of the actions taken or proposed to prevent further violations of this nature. Your response should include the dates, either actual or proposed, for completion of the actions.

If you have any questions, you may contact me at 419-373-3016 or by email at patricia.tebbe@epa.ohio.gov.

Sincerely,

Patricia A. Tebbe, P.E.
Division of Surface Water

/jlm
Enclosure
cc:Mike Carson
Tracking

Compliance Data for Riverview MHP between 12/1/2012 to 6/1/2013

Summary

Permit Effluent Limit Violations: 19

Limit Violations						
Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
December 2012	001	pH	1D Conc	6.5	5.5	12/6/2012
December 2012	001	Dissolved Oxygen	1D Conc	5.0	2.2	12/14/2012
December 2012	001	pH	1D Conc	6.5	5.8	12/14/2012
December 2012	001	Dissolved Oxygen	1D Conc	5.0	.8	12/17/2012
December 2012	001	pH	1D Conc	6.5	5.5	12/17/2012
December 2012	001	Dissolved Oxygen	1D Conc	5.0	1.6	12/26/2012
January 2013	001	Dissolved Oxygen	1D Conc	5.0	4.7	1/2/2013
January 2013	001	pH	1D Conc	6.5	6.1	1/2/2013
February 2013	001	Dissolved Oxygen	1D Conc	5.0	2.1	2/16/2013
February 2013	001	Dissolved Oxygen	1D Conc	5.0	3.6	2/25/2013
March 2013	001	Dissolved Oxygen	1D Conc	5.0	3.9	3/17/2013
March 2013	001	Dissolved Oxygen	1D Conc	5.0	4.7	3/26/2013
March 2013	001	Dissolved Oxygen	1D Conc	5.0	4.6	3/29/2013
April 2013	001	Dissolved Oxygen	1D Conc	5.0	4.	4/15/2013
April 2013	001	Dissolved Oxygen	1D Conc	5.0	2.1	4/23/2013
May 2013	001	Total Suspended Solids	30D Conc	30.0	36.	5/1/2013
May 2013	001	CBOD 5 day	30D Conc	25.0	39.	5/1/2013
May 2013	001	Dissolved Oxygen	1D Conc	5.0	2.4	5/2/2013
May 2013	001	Dissolved Oxygen	1D Conc	5.0	3.8	5/17/2013