



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

July 3, 2013

Re: Scioto County
Clay PK-12 School
Storm Water Construction Activity
Permit # 0GC01276*AG

Mr. Todd Warnock
Clay Local School District
44 Clay High Street
Portsmouth, Ohio 45662

Mr. Dick Spencer
State Farm Insurance
926 Gay Street
Portsmouth, Ohio 45662

Dear Mr. Warnock and Mr. Spencer:

On June 11, 2013, I visited the site located on Clay High Street that has a construction storm water permit with the Ohio EPA. The purpose of my inspection was to determine the compliance of this site with the National Pollutant Discharge Elimination System (NPDES) permit for discharges of storm water associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111.


No violations of the terms and conditions of the permit were discovered. Please continue to implement permit requirements as construction continues. As a note, the fill site located across the street, which is the property of Dick Spencer, is included in this stormwater permit. Therefore, stabilization of this area is required before the permit can be terminated.

I spoke with Sally Spencer on June 13, 2013 and she said seed was placed on the soil. In order to help prevent erosion and aid in vegetation growth, Ohio EPA recommends placing straw over the seeded area. Again, proper stabilization is required in order for Clay Local School District to be released from their General Stormwater Permit requirements.

As a reminder, if your project disturbs more than five acres you are required to implement post construction water quality volume storage requirements with permanent storm water management structures as required by the permit.

If there are any questions, please contact Aaron Wolfe at (740) 380-5277 or myself at (740) 380-5447.

Sincerely,

A handwritten signature in black ink that reads "Jared Kemper". The signature is written in a cursive style with a large, sweeping initial "J".

Jared Kemper
Storm Water Section
Division of Surface Water

JK/dh