



John S. Kasich, Governor
Mary Taylor, Lt. Governor
Scott A. Holtz, Director

July 3, 2013

Bill Koniewich
Westerville Square Inc.
2000 West Henderson Road #500
Columbus, OH 43220

**Re: Notice of Termination Inspection at Westerville Square Shopping Center/
Franklin County. Permit #: 4GC03840*AG**

Dear Mr. Koniewich,

This letter is written in follow up to a construction storm water inspection by Jerome Hoke and Paul Hafner of the Ohio EPA, conducted at Westerville Square Shopping Center located at the Northeast corner of South State Street and East Schrock Road on June 20, 2013. The purpose of the inspection was to evaluate compliance with Ohio EPA's General Storm Water Permit Associated with Construction Activities.

It appeared during the inspection that construction activity has been completed for this site. A Notice of Termination will be required provided the post construction requirements are met. Please address the following:

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction mandates can be found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria with your submittal.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities.
- A Notice of Termination (NOT) must be submitted once the post construction requirements are verified. The NOT form and filing instructions can be found at: <http://www.epa.state.oh.us/dsw/storm/stormform.aspx>.

Bill Koniewich
Westerville Square Inc.
Page 2

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844.

Sincerely,

A handwritten signature in dark ink, appearing to read "Harry Kallipolitis", written over the word "Sincerely,".

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

HK/nsm Westerville Square Shopping Center 6-20-13