



John R. Smith, Commissioner  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

July 3, 2013

Jeff Krebs  
Lincoln Construction  
4790 Shuster Road  
Columbus, Ohio 43214

**Re: Construction Storm Water Inspection at The Crossing Community Church/ Franklin County. Permit Number: 4GC03936 \*AG**

Dear Mr. Krebs

This letter is written regarding a storm water inspection that Jerome Hoke and Samuel Marotta conducted at The Crossing Community Church located at 4770 Britton Parkway in Franklin County on June 18, 2013. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

**Sediment and Erosion Control:**

- The perimeter silt fence is installed and properly functioning on this date. Please ensure continued maintenance via your mandated self-inspection reports every seven days or within 24 hours of a rain event equal to or greater than 0.5 inches.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us).

Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

HK/nsm The Crossing Community Church 6-18-2013