



moving forward

John R. Kasich, Governor
Mike Taylor, Lt. Governor
Scott J. Valle, Director

July 9, 2013

Brian Keeping
Tharaldson Hospitality Development
3549 153rd Avenue, SE
Casselton, ND 58012

**Re: Construction Storm Water Inspection at Residence Inn by Marriott / Delaware County,
Permit Number: 4GC03808*AG**

Dear Mr. Keeping:

This letter is written regarding storm water inspections I conducted at the Residence Inn by Marriott located at 8865 Lyra Drive on June 12 and June 19, 2013. The purpose of these inspections was to evaluate compliance with the General Storm Water Permit associated with Construction Activities. During the inspection, I noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- Sediment controls are implemented in accordance with the General Storm Water Permit. The site is currently surrounded by silt fencing that is functioning as intended. Please maintain all sediment and erosion controls via the mandated self-inspections, every seven days or within 24 hours of a rain event equal to or greater than 0.5 inches.
- I evaluated the subsurface drainage system. As a result of active construction, I will be requiring the removal of all sediment accumulated within the system immediately following final stabilization.

If you have any question regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. A follow up inspection will be conducted to ensure the conditions of the General Permit are met.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Dann Heit, Site Superintendent, dheit@tharaldsonco.com

HK/nsm Residence Inn by Marriott 6-19-2013