



John A. Kasich, Governor  
Mike Taylor, Lt. Governor  
Scott A. Bailey, Director

July 9, 2013

Doug Kaiser  
CP One LLC  
328 Civic Center Drive  
Columbus, OH 43215

**Re: Construction Storm Water Inspection at Centerpoint Building 5 and Infrastructure IMPR / Franklin County. Permit Number: 4GC03940 \*AG**

Dear Mr. Kaiser:

This letter is written regarding a storm water inspection conducted by Sam Marotta and Paul Hafner, of the Ohio EPA at Construction Storm Water Inspection at Centerpoint Building 5 and Infrastructure IMPR located at NW of Toy Road and Swisher Road on June 19, 2013. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

**Sediment and Erosion Control:**

- Our staff noted that the sediment and erosion controls on site were functioning properly. Please continue to maintain silt fencing to ensure future working order.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us).

Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

HK/nsm Centerpoint Buildint 5 and Infrastructure IMPR 7-13