



40 years



John E. Kasich, Governor
Mary Taylor, M. Governor
Scott L. Kelly, Director

July 5, 2013

Jim Lipnos
Homewood Corporation
2700 E. Dublin-Granville Road, Suite 300A
Columbus, OH 43231

Re: Construction Storm Water Inspection at Copperfield Section 3, Phases I & II/ Madison County, Permit Number: 4GC03948 *AG

Dear Mr. Lipnos:

This letter is written regarding a storm water inspection conducted by Elizabeth Pleta and Rachel Bellis of the Ohio EPA at Copperfield Section 3, Phases I & II located at Alcott Drive on June 24, 2013. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- Our staff noted the inlet protection along Hawthorne Drive and Cooper Drive require maintenance (See Figure 1).

Barren Areas:

- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

HK/nsm Copperfield Section 3 Phases I II 6-25-13



Figure 1 Inlet protection located on Hawthorne Drive.