



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

Re: Fulton County  
Indian Hill Plat 3  
Storm Water Construction  
Permit No. 2GC01337\*AG

July 10, 2013

Mr. Frank Munian  
Munian Developments Inc.  
506 Layer Road  
Holland, Ohio 43528

Dear Mr. Munian:

On June 12, 2013, I conducted an inspection of the Indian Hill Plat 3 subdivision located south of US 20-A in the Village of Swanton, Fulton County. The purpose of this visit was to evaluate compliance of the site with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity also known as the Construction General Permit (CGP). Observations made are under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111.

The CGP was issued to Munian Developments Inc. on June 19, 2006. Construction on this project does not appear to have begun. When construction does begin, it is important to remember the permit requirements for storm water management during construction and post construction, such as weekly self-inspections, the requirement to apply cover on bare soil in any areas that will sit idle for more than 21 days, maintaining sediment and erosion controls, and installing post construction controls. Your sediment controls must be installed within seven days of grubbing and before any grading. You should refer to Ohio's *Rainwater and Land Development Manual* (ODNR) for proper installation and maintenance of erosion and sediment control practices.

If you have any questions, you may contact me at (419) 373-3016 or by e-mail at [patricia.tebbe@epa.ohio.gov](mailto:patricia.tebbe@epa.ohio.gov).

Sincerely,

A handwritten signature in cursive script that reads 'Patricia A. Tebbe'.

Patricia A. Tebbe, P.E.  
Division of Surface Water

/jlm

ec: Fulton County SWCD  
Fulton County Engineer  
Tracking