



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Ashland County
Loudonville Dollar General
Construction Storm Water
Facility ID No. 2GC03019*AG

July 10, 2013

Mr. Mark Bush
Loudonville DG, LLC
361 Summit Boulevard, Suite 110
Birmingham, Alabama 35243

Dear Mr. Bush:

On July 1, 2013, Zachary Titkemeier and I inspected the Loudonville Dollar General on 810 South Market Street, Loudonville (photos taken). The purpose of our visit was to evaluate compliance of the site with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111.

It appears that construction activities at the Loudonville Dollar General are complete. A finished building and paved drives were present. The facility had been open for business for over a year. The post-construction storm water management requirements appear to have been met by the creation of a swale along the east property line and an extended detention pond south of the parking lot. A very light cover of grass had been established throughout most of the disturbed land, with some bare patches remaining. A Notice of Termination (NOT) must be filed to relieve you of the obligation to comply with this general permit. An NOT may be filed if one or more of the following conditions have been met:

- Final stabilization has been established on all areas of the site for which the permittee is responsible. Final stabilization means that all soil disturbing activities at the site are complete and a uniform perennial vegetative cover of at least 70% density has been established over the entire site. All temporary erosion and sediment control measures have been removed, properly disposed of, and all trapped sediment has been permanently stabilized; or
- Another operator(s) has assumed control over all areas of the site that have not been fully stabilized.

Mr. Mark Bush
July 10, 2013
Page Two


Once you have met these criteria by stabilizing the patches of bare soil and reaching a sufficient vegetative density throughout the site, you may file the NOT form. The NOT form and instructions can be found on our website:

<http://www.epa.ohio.gov/dsw/storm/stormform.aspx>

NOTs must be mailed to Ohio EPA's Central Office within 45 days of when the above criteria are met.

If there are any questions, please contact me at 419-373-3011.

Sincerely,



Tom Wilkins
Division of Surface Water
Storm Water Program

/jlm

ec: Mr. Curt Young, Village Administrator, Village of Loudonville
Tracking