



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Wyandot County
The Olen Corp (Upper Sandusky)
NPDES Permit

July 10, 2013

Mr. Kenneth Holland
The Olen Corporation
4755 South High Street
Columbus, Ohio 43207

Dear Mr. Holland:

This will acknowledge our June 26, 2013, compliance inspection at your Upper Sandusky facility. This facility is located on 6326 County Road 61, Upper Sandusky. This inspection was conducted to evaluate compliance with your facility's National Pollutant Discharge Elimination System (NPDES) permit No. 2IJ00067 (OH0058360).

At the time of the inspection, Outfall 001 was discharging. No oil sheen was noted on the settling pond. When a discharge occurs from the pond, it must be sampled in accordance with this NPDES permit. Please note that your NPDES permit will expire on July 31, 2017.

Our review of your Discharge Monitoring Reports (1/1/2012 to 6/1/2013) for this facility indicated two effluent violations. Please refer to the enclosed violation table. A completed inspection report is included for your review. If you have any questions or comments, please call me at 419-373-3021.

Sincerely,

A handwritten signature in black ink, appearing to read "Jason Ko", is written over a circular stamp or seal.

Jason Ko
Division of Surface Water

/jlm

Enclosures

ec: Tracking

NPDES COMPLIANCE INSPECTION REPORT

Section A: National Data System Coding

Permit #	NPDES	Yr/Mo/Day	Inspection Type	Inspector	FacType
21J00067	OH0058360	2013/6/26	C	S	2

Section B: Facility Data

Name and Location of Facility Inspected The Olen Corporation (Upper Sandusky Plant) 6326 County Road 61 Upper Sandusky, OH 43351	Entry Time	Permit Effective Date
	Exit Time	Permit Expiration Date
	1:15 PM	8/1/2012
	1:45 PM	7/31/2017

Name(s) and Title(s) of On-Site Representative(s)	Phone Number(s)
Mr. Scott Shaver, Area Production Manager	(419) 294-2611

Name, Address and Title of Responsible Official	Phone Number
Mr. Kenneth Holland, President The Olen Corporation 4755 South High Street Columbus, OH 43207	(614) 491-1515

Section C: Areas Evaluated During Inspection (S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)

<u>S</u> Permit	<u>--</u> Flow Measurement	<u>--</u> Pretreatment
<u>N</u> Records/Reports	<u>--</u> Laboratory	<u>--</u> Compliance Schedules
<u>S</u> Operations & Maintenance	<u>S</u> Effluent	<u>S</u> Self-Monitoring Program
<u>S</u> Facility Site Review	<u>--</u> Sludge Storage/Disposal	<u>--</u> Other

Section D: Summary of Findings/Comments (Attach additional sheets if necessary)

- * Outfall 001 was discharging & No oil sheen was noted
- * Current NPDES permit will expire on 7/31/2017
- * A review of Discharge Monitoring Reports (1/1/2012 – 6/1/2013) indicated two effluent violations

 Jason Ko Name(s) and Signature(s) of Inspector(s)	Date	7/10/13 Ohio EPA, Northwest District Office
---	------	--

 Thomas Poffenbarger, P.E. Name and Signature of Reviewer	Date	7/2/13 Ohio EPA, Northwest District Office
--	------	---

Get New Data

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
21J00067*GD	January 2013	001	00530	Total Suspended Solids	1D Conc	45.0	67.	1/18/2013
21J00067*GD	January 2013	001	00530	Total Suspended Solids	30D Conc	30.0	67.	1/1/2013