



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

July 15, 2013

Mr. Robert Heintz
Bunnell Hill Construction
3000 G Henkle Drive
Lebanon, OH 45036

RE: FedEx Ground; NPDES Permit # 1GC04209*AG; Notice of Violation Follow Up Inspection

Dear Mr. Heintz:

On Tuesday, July 5, 2013, I returned to the Fed Ex Ground project located in Lebanon, Ohio, to conduct a follow up to the Notice of Violation cited on June 10, 2013. I walked the property but did not meet with anyone on the site.

In your response to the Notice of Violation on June 14, 2013, you indicated that check dams that had been blown out would be reworked and reseeding of a slope on the south end of the property would take place. During my follow up inspection I was pleased to see that these actions had indeed taken place.

With the reworked check dams and the final stabilization that has been achieved on and around the property there is no longer any violation of the permit. In fact, because all land disturbed by various construction activities appeared to have been adequately stabilized with landscaping or the planting of grass and/or other vegetation, you are ready to submit a Notice of Termination for the site.

This one page form is available at http://www.epa.ohio.gov/Portals/35/permits/General_NOT.pdf. It must be completed and sent to the following address:

Ohio Environmental Protection Agency
General Permit Program
PO Box 1049
Columbus, OH 43216-1049

Mr. Robert Heintz
FedEx Ground
July 15, 2013
Page 2

If you have questions regarding this letter you can contact me at (937) 204-1003 or via email at eric.damian@epa.ohio.gov.

Sincerely,

A handwritten signature in black ink, appearing to read "Eric Damian", with a long horizontal flourish extending to the right.

Eric Damian
Storm Water Group
Division of Surface Water