



Inah B. Kosich, Governor
Mike Taylor, Lt. Governor
Scott S.rafy, Director

July 9, 2013

Father David Sizemore
Saint John Neumann Catholic Church
801 West Cherry Street, Suite 120
Sunbury, Ohio 43074

**RE: Construction Storm Water Inspection at Saint John Neumann Catholic Church/ Delaware County,
Permit Number: 4GC03556*AG**

Dear Father Sizemore,

This letter is written regarding a storm water inspection I conducted at Saint John Neumann Catholic Church located at 9633 State Road 37 on July 2, 2013. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Pre-Construction Requirements:

- Based on my site evaluation, it appears the retention basin does not meet the requirements of the General Storm Water Permit. Specifically, a fore bay and micro pool must be established to accommodate 20% of the water quality volume designed for this impoundment. At this time I am requesting the design calculation for review to ensure the water quality volume and the associated de-watering time has been properly addressed. In addition, please ensure the installation of the fore bay and micro pool within 10 days from receipt of this letter or demonstrate an approvable alternative.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. In addition, please provide a written response (**email preferred**) to the action items addressed above within ten days from receipt of this letter. A follow up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Ohio EPA, Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/slw

Saint John Neumann Catholic Church 7-2-13