



40 years of moving forward

John R. Kasich, Governor  
Mike DeWine, Governor  
Scott J. Broun, Director

July 11, 2013

Robert Kibler  
Ohio Department of Agriculture  
8995 East Main Street  
Reynoldsburg, Ohio 43068

**RE: Notice of Termination Inspection at Ohio Department of Agriculture/  
Licking County, Permit Number: 4GC03930\*AG**

Dear Mr. Kibler,

This letter is written in follow up to a construction storm water inspection by Jerome Hoke and Paul Hafner of the Ohio EPA, at the Ohio Department of Agriculture located at 8995 East Main Street on July 2, 2013. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities.

It appeared during the inspection that construction activity has been completed for this site. A Notice of Termination form is required provided the following items are addressed:

- All areas must be protected from erosion measured by a minimum vegetative density of 70 percent for all disturbed areas.
- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction mandates can be found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCOA.aspx>. Please submit to my attention (email preferred at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us)) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria with your submittal.
- If the vegetative requirements above are met please submit your Notice of Termination (NOT) concurrent with your submittal of the post construction

Robert Kibler  
Ohio Department of Agriculture  
Page -2-

verification. The NOT form can be found at:

[http://www.epa.state.oh.us/portals/155/documents/NOT\\_app\\_3.pdf](http://www.epa.state.oh.us/portals/155/documents/NOT_app_3.pdf)

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844.

Sincerely,



Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO