



John R. Kasich, Governor  
Mike Taylor, Lt. Governor  
Scott J. Wells, Director

July 10, 2013

Fischer Homes  
570 Polaris Parkway  
Suite 125  
Westerville, OH 43082

**Re: Villages at Westchester / Franklin County**

To Whom it May Concern:

This letter is written in follow-up to a construction storm water inspection that I conducted on June 28, 2013, at the Villages of Winchester, Sec. 11, located near the intersection of Dietz Drive and Gender Road, in Canal Winchester, Ohio. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit associated with Construction Activities. During the inspection, I noted the following:

**Sediment and Erosion Control:**

- There were two homes under construction. Erosion controls were installed at the one site and were being installed at the second site. Please be aware that the second site was nearly complete and the erosion controls were just being installed. The erosion controls should be installed with the initial earth disturbance.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3851.

Sincerely,

Gregory L. Sanders  
Environmental Specialist  
Division of Surface Water  
Central District Office

GS/nsm Villages at Westchester, June 28, 2013