



John E. Kasich, Governor
Nancy Taylor, Lt. Governor
Harry Kallipolitis, Director

July 11, 2013

Micheal Barker
City of Westerville
21 South State Street
Westerville, Ohio 43081

RE: Construction Storm Water Inspection at Westerville Service Complex/ Franklin County Permit Number: 4GC04121*AG

Dear Mr. Barker,

This letter is written regarding a storm water inspection conducted by Paul Hafner and Jerome Hoke of the Ohio EPA at Westerville Service Complex located at 350 Park Meadow Road on June 26, 2013. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- Our staff noted sediment had collected on the entrance way of the site; please ensure proper measures are addressed to minimize sediment on public streets.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. In addition, please provide a written response (**email**

Micheal Barker
City of Westerville
Page -2-

preferred) to the action items addressed above within ten days from receipt of this letter. A follow up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Ohio EPA, Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO



Westerville Service Complex
Mum Creek Watershed
Photo by Jerome Hoke
6-26-10

Figure 1 Sediment Collection on Road Way