



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

July 22, 2013

Re: Meigs County
Meigs County EMS
No Exposure
Industrial Storm Water
Permit #0GRN00104*DG

Ms. Lorri Dolin Reynolds
Meigs County EMS
119E Memorial Drive
P.O. Box 748
Pomeroy, Ohio 47560

Dear Ms. Reynolds:

On June 10, 2013, I conducted an inspection of your facility. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. As a result of the inspection, I have the following comment:

Your facility appeared to be in compliance with the No Exposure Waiver that has been issued to you by the Ohio EPA. Please continue to implement requirements in the future. Please note, at the time of inspection, there was a crack in the concrete that the fuel tanks sit on. Please seal this crack to ensure no fuel leaks out of the containment area.

If you have any questions, please contact me at (740) 380-5447 or my supervisor Aaron Wolfe at (740) 380-5277.

Sincerely,

A handwritten signature in black ink that reads "Jared Kemper". The signature is written in a cursive style.

Jared Kemper
Storm Water Section
Division of Surface Water

JK/dh