



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

July 18, 2013

Mr. Bradley Neavin  
Eaton Community Schools  
307 North Cherry Street  
Eaton, OH 45320

**RE: Eaton Middle School; NPDES Permit #1GC04065\*AG; Compliance Inspection Findings**

Dear Mr. Neavin:

On Tuesday, July 16, 2013, I inspected the Eaton Middle School site in Eaton, Ohio, to determine compliance with the site's NPDES construction site storm water discharge permit. I did not speak with anyone during the inspection. The reason for the inspection was for a follow-up from the Notice of Violation issued June 13, 2013.

Based on my observations, there were no obvious violations of the project's storm water discharge permit. I did review the sediment control inspection logs and the site's storm water pollution prevention plan before my inspection. The corrective action for the inlet protection of the storm drains are now preventing any sediment laden water from entering the storm sewer system. This corrective action is now complying with the NPDES general construction permit.

As a reminder, please note that when construction is complete, and all areas of the site have been permanently stabilized with vegetation or other ground cover, the construction permit must be terminated. A one page "notice of termination" (NOT) form found at [http://www.epa.ohio.gov/Portals/35/permits/General NOT.pdf](http://www.epa.ohio.gov/Portals/35/permits/General%20NOT.pdf) must be completed and sent to the following address:

Ohio Environmental Protection Agency  
General Permit Program  
PO Box 1049  
Columbus, OH 43216-1049

No response to this letter is needed.

Mr. Bradley Neavin  
Eaton Middle School  
July 18, 2013  
Page 2

If you have any questions regarding the NPDES permit you can contact me at (937) 204-1002 or via email at [james.schwieterman@epa.ohio.gov](mailto:james.schwieterman@epa.ohio.gov).

Sincerely,

A handwritten signature in black ink, appearing to read "James Schwieterman", with a long horizontal flourish extending to the right.

James Schwieterman  
Storm Water Group  
Division of Surface Water

JS/kb

ec: Tom Doseck, Eaton Community Schools  
Jeff Williams, Megen Construction

Enclosed: Inspection Sheet

Ohio EPA DSW Storm Water Section, Construction Site Visit Information Form

Inspector initials: JS Visit date: 7/16/13 Permit # 16C04459-A6-16C000057A

Site Name: New Athletic Facilities - Phase 1, Eaton High Middle School

Site Address: 600 Hillcrest Drive Eaton, OH; Asble. County

People Contacted On Site: \_\_\_\_\_

Phone: \_\_\_\_\_ E-mail: \_\_\_\_\_

1. Did you see the following on site? on-line

ITEM	YES	NO	Not Requested	Comments
NOI	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	NOV From 6/13/2013 Follow up
Coverage Letter	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
SWP3	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Inspection Records	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Contractor & Subs signature document	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

2. Acreage Disturbed: 15.0 + 18.9

3. Site Status: Clearing/grubbing Rough Grading Storm sewers in  
Streets in Utilities installed Final Grade Final stabilization  
 ↳ Parking Lot

4. Are BMPs needed: Yes, until permanent stabilization occurs

5. Are BMPs effective? All Some None No BMPs

Explain: Silt fence reinforced in rear of site, Stone Rip Rap, Inlet Protection Fixed

6. What post construction controls are shown on the SWP3? Yes, Sediment ponds intake all storm water on site.

7. Were Photos taken & saved? Yes

8. Was an NOV issued? NO

Additional notes/comments:

Final stabilization once all soil disturbance activities have ceased.  
 Corrective Actions comply with permit.  
 Inlet protection Implemented, Parking Lot near completion