



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

July 18, 2013

Mr. Rodd Hale
Village of Versailles
177 North Center Street
Versailles, OH 45380

RE: State Route 185 Relocation; NPDES Permit #1GC04442*AG; Compliance Inspection Findings

Dear Mr. Hale:

On Tuesday, July 16, 2013, I inspected the State Route 185 relocation project in Versailles, Ohio, to determine compliance with the site's NPDES construction site storm water discharge permit. I did not speak with anyone on site during the inspection.

Based on my observations, there were no obvious violations of the project's storm water discharge permit. I did not review the sediment control inspection logs or the site's storm water pollution prevention plan before my inspection, but records of inspections of the erosion control BMPs are required to be kept. With the excavating phase underway, the erosion controls installed so far meet the requirements for the sites storm water discharge permit. Once the storm drains are installed, some variation of inlet protection device must be installed to prevent sediment laden water from entering an active storm sewer system. Refer to ODNR's Rainwater and Land Development Manual (Ch.6, Sec. 4, Pg. 35-43) for further assistance.

No response to this letter is needed.

If you have any questions regarding the NPDES permit you can contact me at (937) 204-1002 or via email at james.schwieterman@epa.ohio.gov.

Sincerely,

James Schwieterman
Storm Water Group
Division of Surface Water

JS/kb

Enclosed: Inspection Sheet

