

July 11, 2013

Carrie Hiatt
Whitehall Elderly Facilities LP
562 East Main Street
Columbus, Ohio 43215

**RE: Construction Storm Water Inspection at Eastway Village 202 / Franklin County
Permit Number: 4GC03973 *AG**

Dear Ms. Hiatt:

This letter is written regarding a storm water inspection conducted by Sam Marotta and Rachel Bellis of the Ohio EPA at Eastway Village 202 located at 562 East Main Street on June 27, 2013. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- Please re-cover drains to maintain inlet protection (See Figure 1).
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days (See Figure 2).

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. In addition, please provide a written response (**email preferred**) to the action items addressed above within ten days from receipt of this letter. A follow up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Ohio EPA, Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW / CDO




Figure 1: Inlet protection needs maintained.




Figure 2: Barren areas require protection from erosion after 21 days of inactivity.