



40 years and moving forward

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Maly, Director

July 22, 2013

Rich Conie
Maronda Homes, Inc.
3811 Twin Creeks Drive
Columbus, OH 43204

Re: Spangler Farms, Franklin County

Dear Mr. Conie:

This letter is written in follow-up to a construction storm water inspection that I conducted on July 2, 2013, at Spangler Farms located at 2699 Spangler Road, in Columbus, Ohio, on October 20, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following:

Sediment and Erosion Controls:

There was no active construction during my inspection. The site was stabilized and no erosion appeared to be leaving the site. If construction does start again, please be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities.

If you have any questions regarding this letter or my inspection, please do not hesitate to call me at our Central District Office at (614) 728-3851.

Sincerely,

Gregory L. Sanders
Environmental Specialist
Stormwater Section
Division of Surface Water
Central District Office

GS/hsm Spangler Farms, July 2, 2013