



40 years and moving forward

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Smith, Director

July 26, 2013

Doug Swartz  
Columbus City Schools Department of Facilities  
889 East 17<sup>th</sup> Avenue  
Columbus, OH 43215

**Re: Notice of Termination Inspection at Fort Hayes / Franklin County Permit Number:  
4GC03787\*AG**

Dear Mr. Swartz:

This letter is written in follow-up to a construction storm water inspection by Paul Hafner and Sam Marotta of the Ohio EPA, at Fort Hayes located at 546 Jack Gibbs Boulevard on July 3, 2013. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

It appeared during the inspection that construction activity has been completed for this site. A Notice of Termination form is required provided the following items are addressed:

- All areas must be protected from erosion measured by a minimum vegetative density of 70 percent for all disturbed areas.
- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction mandates can be found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us)) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria with your submittal.
- If the vegetative requirements above are met please submit your Notice of Termination (NOT) concurrent with your submittal of the post construction verification. The NOT form can be found at: [http://www.epa.state.oh.us/portals/35/documents/NOT\\_app\\_fis.pdf](http://www.epa.state.oh.us/portals/35/documents/NOT_app_fis.pdf)

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844.

Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

HK/nsm Fort Hayes 7-3-13

Central District Office • 50 West Town Street • Suite 700 • P.O. Box 1049 • Columbus, OH 43216-1049  
[www.epa.ohio.gov](http://www.epa.ohio.gov) • (614) 728-3778 • (614) 728-3898 (fax)