

July 26, 2013

Todd Sloan  
The Daimler Group  
1533 Lake Shore Drive  
Columbus, OH 43204

**Re: Construction Storm Water Inspection at Exhibit Pro / Licking County  
Permit Number: 4GC04055\*AG**

Dear Mr. Sloan:

This letter is written regarding a storm water inspection conducted by Brittany Turner and Rachel Bellis of the Ohio EPA at Exhibit Pro located at Smiths Mill Road on July 1, 2013. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

**Sediment and Erosion Control:**

- Our staff observed the retention pond has become overburdened with sediment near the inlet (See Figure 1). Please be aware sediment traps must be utilized for areas of concentrated flow and must be sized with a required sediment storage volume per the General Permit. These sediment impoundments will require cleaning once they have exceeded 50 percent of their capacity.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days (See Figure 2).

**Post Construction Requirements:**

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us)) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

Todd Sloan  
The Daimler Group  
Page 2


If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us).

Sincerely,

A handwritten signature in black ink, appearing to read "Harry Kallipolitis". The signature is fluid and cursive, with the first name being the most prominent.

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

HK/nsm Exhibit Pro 7-1-2013



**Figure 1: Pond on site**



**Figure 2: Barren Area**