



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

July 22, 2013

RE: SUMMIT COUNTY  
TWINSBURG TOWNSHIP  
AMBASSADORS IN SPORT  
3819 EAST AURORA ROAD  
CEI/NOTICE OF VIOLATION

**CERTIFIED MAIL**

Ambassadors in Sport – Freedom Center Church  
Attn: Mr. Jonathan Ortlip, Director  
P.O. Box 847  
Twinsburg, OH 44087

Dear Mr. Ortlip:

On July 10, 2013, a Compliance Evaluation Inspection (CEI) was conducted at the wastewater treatment plant (WWTP) serving Ambassadors in Sport. The purpose of the inspection was to observe the operation and maintenance of the plant, and to determine whether the facility has been in compliance with its National Pollutant Discharge Elimination System (NPDES) permit.

During the inspection, the following observations and/or deficiencies were noted:

1. The mixed liquor in the extended aeration tank was being properly aerated, was the appropriate chocolate brown color, and was not odorous. The sludge return line appeared to be working properly.
2. The surface sand filters require additional maintenance. It does not appear that new sand has been installed as is required by your NPDES permit's compliance schedule. The sand filter contained lots of solids which need to be raked out. These solids shall be placed in a watertight container prior to being put with the remainder of the site's trash, which ultimately is disposed at a properly permitted landfill.
3. The disinfection tank appeared to contain some solids, rather being clear. Also, it does not appear that a second tablet dispenser (for dechlorination tablets) has been added to the tank as is required by your compliance schedule. Without dechlorination tables, there is no guarantee that your effluent will meet its low chlorine residual limitation.
4. For safety/liability reasons, it is strongly recommended that you install a six foot high locked fence around the entire WWTP.


Review of the electronic Discharge Monitoring Reports (eDMRs) reported for your plant from June 1, 2011 through June 2013, revealed the following effluent violations:

Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
March 2012	Total Suspended Solids	30D Conc	12	15.	3/1/2012
June 2012	Total Suspended Solids	30D Conc	12	14.	6/1/2012
June 2012	Nitrogen, Ammonia (NH3	30D Conc	1.0	4.3	6/1/2012
June 2012	Nitrogen, Ammonia (NH3	7D Conc	1.5	4.3	6/15/2012
June 2012	Chlorine, Total Residu	1D Conc	0.019	.21	6/20/2012
August 2012	Nitrogen, Ammonia (NH3	30D Conc	1.0	1.4	8/1/2012
August 2012	Chlorine, Total Residu	1D Conc	0.019	.07	8/24/2012
March 2013	pH	1D Conc	6.5	6.22	3/18/2013
March 2013	Total Suspended Solids	30D Conc	12	18.	3/1/2013
March 2013	Nitrogen, Ammonia (NH3	30D Conc	3.0	4.75	3/1/2013
March 2013	Nitrogen, Ammonia (NH3	7D Conc	4.5	4.75	3/15/2013

Please be advised such instances of noncompliance are subject to enforcement pursuant to Ohio Revised Code 6111.

In conclusion, this office directs that you, with the assistance of your certified WWTP operator, provide a written explanation and correction plan concerning the above mentioned deficiencies and violations. If you have any questions concerning this letter, please contact this office at (330) 963-1151.

Sincerely,



Jennifer S. Bennage  
Environmental Engineer  
Division of Surface Water

JSB/cs

ec: Tom LaPlante, Summit County Health Dept.  
Michael Zronek, Technical WW Operator

**U.S. Postal Service™**  
**CERTIFIED MAIL™ RECEIPT**  
*(Domestic Mail Only; No Insurance Coverage Provided)*

For delivery information visit our website at [www.usps.com](http://www.usps.com)

**OFFICIAL USE**

7012 3050 0001 8843 1405

Postage	\$
Certified Fee	
Return Receipt Fee (Endorsement Required)	
Restricted Delivery Fee (Endorsement Required)	
Total Postage & Fees	\$

Postmark  
Here

Sent To

Street, Apt. No.;  
or PO Box No.

City, State, ZIP+4

PS Form 3800, August 2006

See Reverse for Instructions

SENDER: COMPLETE THIS SECTION	COMPLETE THIS SECTION ON DELIVERY
<ul style="list-style-type: none"> <li>Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.</li> <li>Print your name and address on the reverse so that we can return the card to you.</li> <li>Attach this card to the back of the mailpiece, or on the front if space permits.</li> </ul>	<p>A. Signature <input checked="" type="checkbox"/> Agent  <input checked="" type="checkbox"/> Addressee</p> <p>B. Received by (Printed Name) <i>Annethilly</i> C. Date of Delivery <i>7/23/13</i></p> <p>D. Is delivery address different from item 1? <input type="checkbox"/> Yes            If YES, enter delivery address below: <input type="checkbox"/> No</p>
<p>1. Article Addressed to:</p> <p><b>Ambassadors in Sport –            Freedom Center Church            Attn: Mr. Jonathan Ortlip, Director            P.O. Box 847            Twinsburg, OH 44087</b></p>	<p>3. Service Type  <input checked="" type="checkbox"/> Certified Mail <input type="checkbox"/> Express Mail  <input type="checkbox"/> Registered <input type="checkbox"/> Return Receipt for Merchandise  <input type="checkbox"/> Insured Mail <input type="checkbox"/> C.O.D.</p>
<p>2. Article Number            (Transfer from service label) <i>7012 3050 0001 8843 1405 DSW</i></p>	<p>4. Restricted Delivery? (Extra Fee) <input type="checkbox"/> Yes</p>

PS Form 3811, February 2004

Domestic Return Receipt

*7-22-13*

102595-02-M-1540

