



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

July 31, 2013

Chad Doll
National Lime and Stone CO
2406 South Section Line Road
Delaware, Ohio 43015

**RE: Construction Storm Water Inspection at National Lime and Stone CO / Franklin County.
Permit Number: 4GC03695*AG**

Dear Mr. Doll,

This letter is written regarding a storm water inspection conducted by Jerome Hoke and Rachel Bellis of the Ohio EPA at National Lime and Stone CO located at 4350 Fisher Road on July 17, 2013. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- Sediment controls on site appear to be in good working order. Please ensure that all sediment controls are inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on site for the agency to review.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely

A handwritten signature in black ink, appearing to read 'Harry Kallipolitis', written over a white background.

Harry Kallipolitis
Storm Water Coordinator
Ohio EPA
Division of Surface Water

c: Jeff Bohne, Water Quality Supervisor, DSW / CDO